



Latrobe Corporate Office
1004 Ligonier Street, PO Box 853
Latrobe, PA 15650
Phone: 724-539-8562
Fax: 724-539-3697
www.gibson-thomas.com

November 4, 2024

CLARIFICATION NO. 1

PROJECT: Fayette County Commissioners
Sheepskin Trail
Contract – 2/2024

BID OPENING: November 14th @ 3:00 p.m.

CLARIFICATION:

- Bid item 8 and 9 calls out pounds to include mulch – but the quantities are only 529#s for #8 and 69#s for #9 – how should they call this out for pricing when it's such a small amount?
 - **It is recognized that these are relatively smaller quantities, but the Contractors should price them as they deem appropriate.**
- There are wood walls in the right-of-way are these being removed or left in?
 - **The wood walls are to remain in place.**
- Item #23 – Selective Coarse Aggregate #1 – is this RCE stone or what is this for?
 - **Line Item #23 is associated with the As-Directed Undercut Detail. To be clear, Line Items #22 – Class 1C Excavation, #23 – Selected Borrow Excavation, Coarse Aggregate No 1, & #24 – Geotextile, Class 4, Type C are all associated with the As-Directed Undercut Detail.**
- Item #9000-0004 6" Pipe, in Section VII says that the pipe is to have perforations. Under material, it does not have No. 57 aggregate or geotextile.
 - **Bid this item as perforated pipe without No. 57 aggregate or geotextile, as per the specification.**
- Also, for Item #9000-0004, can any pipe material under Pub 408, Section 601.2 be used, or does it have to be PVC Sch 40 pipe.
 - **Bid this item as Schedule 40 PVC pipe, as per the specification.**

CLARIFICATION #1 – Contract 2/2024 – Sheepskin Trail Project

Please acknowledge receipt of this clarification by signing accordingly and returning this page by email.

Name of Company (please print)

Signature

Date

ESTABLISHED 1916